

Is climate data given sufficient consideration in building design?



*Richard Quincey MEng CEng MCIBSE
Technical Director IES Ltd.*

Typically



... users pick default weather data; no questions asked

... they assume it is representative & appropriate for the task

... they do not consider weather data file variability nor sensitivity to climate change

25 years ago

	Summer °C
San Francisco	28/18
London	28/20
Singapore	33/28



Winter °C



3

-4

22

1kB

15 years ago



http://apps1.eere.energy.gov/buildings/energyplus/weatherdata_simulation.cfm

ASHRAE heat balance method

100kB

Questions to ask




Compare metrics




Look for typical / atypical data

Check what was it created for

Check how it was created



http://apps1.eere.energy.gov/buildings/energyplus/weatherdata_simulation.cfm



Pittsburgh Intl Airport

ASHRAE 90.1¹ 5A Cool humid
 Köppen- Dfb Humid snow (cold winters), Fully humid, no dry season, Warm summer (marine), Geiger²
 Chosen weather file is USA_PA_Pittsburgh_TMY2.epw
 Rainfall location: Pittsburgh, USA
 Winter is potentially most dominant - the design must minimize heating energy.
 Latitude is mid - solar radiation on south/east/west walls is significant. Solar radiation on roofs is significant.
 Summer is warm. Summer also has a large diurnal range. Summer also has cool summer nights.
 Winter is cold.
 Winter prevailing winds typically from the north. Summer prevailing winds typically from the south. Wind patterns: Typically westerly winds.
 Annual cloud cover is high (affects access to solar energy).

Temperature³:

Warmest month Aug
 Max annual temperature (Jun) 33.3 °C
 Warmest six months Aug Jul Jun Sep May Oct
 Coldest month Jan
 Min annual temperature (Jan) -18.9 °C
 Coldest six months Jan Feb Dec Nov Mar Apr
 Number of months warmer than 10.0 °C mean = 6

Diurnal temperature swing³:

0 months swing > 20 °C, of which 0 are in the warmest 6M
 0 months swing 15 to 20 °C, of which 0 are in the warmest 6M
 8 months swing 10 to 15 °C, of which 6 are in the warmest 6M
 4 months swing 5 to 10 °C, of which 0 are in the warmest 6M
 0 months swing < 5 °C

Moisture and humidity⁴:

Max. moisture content 0.022 kg/kg
 Min. moisture content 0.000 kg/kg
 Mean moisture content 0.006 kg/kg
 Mean relative humidity 67.3 %

Wind⁵:

Annual mean speed 3.9 m/s
 Annual mean direction E of N -100.3°

Precipitation⁶:

Annual rainfall 935.9 mm
 Driest month Oct with 59.9 mm rainfall
 Wettest month Jul with 95.3 mm rainfall
 Wettest summer month Jul
 Wettest winter month Mar
 Driest summer month Oct
 Driest winter month Feb
 Wettest six months Jul Jun May Mar Aug Apr

Solar energy⁷:

Annual hourly mean global radiation(a) 157.4 Wh/m²
 Mean daily global radiation(b) 3771.3 Wh/m²
 Annual solar resource(c) 1379.7 kWh/m².yr
 Annual mean cloud cover(d) 6.5 oktas

Degree days⁸:

HDD(18.0) = 3371.3
 CDD(10.0) = 1716.1

Numbers ...

Minima / maxima

Cumulative; solar

Hours thresholds exceeded

Peak months etc

Derived ...




Climate type

Diurnal range

Degree days

.....


Atypical ... Singapore wind



Try to use
period based
real data !

<http://meteonorm.com/products/mete>

What it was created for ...




TRY **5A** HDD **3166** / CDD **844**
 TRY 05 **4A** HDD 2650 / CDD 1150
 9697 **4A** HDD 2599 / CDD 1163
 DSY 05 **4A** HDD **2535** / CDD **1332**

20% spread for
 HDD
 37% spread for
 CDD

Try to use period
 based real data (TMY)
 Use single years for
 specific purposes only

Climate zone issues ... shift ...



		HDD ₁₈	CDD ₁₀
TMY	4C	2057	1287
TMY2	4C	2025	1299
TMY3	3C	1773	1479

Pick representative weather data

How it was created ... interpolated



Use morphed /
interpolated data
very carefully

Acknowledgement: Meteonorm

<http://www.anthem.eu/meteonorm/EN/>

Climate change



Hadley centre models:

Used in


IPCC 2001 assessment

UKCP02 projections


More recently

IPCC 2007 assessment

UKCP09



Global Warming Projections



HadCM3 A2 morphed data (circa 2001)





London:

Current epw

epw 2020

epw 2050

epw 2080



Cold stress Comfortable Hot stress Cold stress Comfortable Hot stress Cold stress Comfortable Hot stress Cold stress Comfortable Hot stress

90.1 5A
 KG Cfb
 HDD 3063
 CDD 926

4A
 Cfb
 2819
 1088

4A
 Cfb
 2497
 1365


4A
 Cfb
 2075
 1774

-33%
 +92%

Effect on plant sizing



Peak ext design temperatures:



UKCIP 09 50%






London: energy sims

Current TRY05

TRY 2030

TRY 2050

TRY 2080



90.1 4A
 KG Cfb
 HDD 2650
 CDD 1150

4A
 Cfb
 2418
 1507

4A
 Cfb
 2245
 1678

4A
 Cfb
 2022
 1906

-24%
 +66%

London: worst case year

Current DSY05

DSY 2030

DSY 2050

DSY 2080



90.1
KG
HDD 2535
CDD 1332

4A
Cfb


4A
Cfb
2418
1507

4A
Cfb
2188
1765


3C
Cfa
1945
1990

-23%
+49%

Heating degree days...




Cooling degree days...



Effect on plant sizing



Peak temperature ...



Conclusions ...



Earlier climate model over-estimated peaks but peak change is still significant

Plant run hours changes HVAC economics & carbon balance ... plant efficiency even more critical than now

2030 data for design yes

2050/80 data for adaption strategy / risk only!



Questions?

richard.quincey@iesve.com

T: 0141 945 8500

www.iesve.com